



CB TEST CERTIFICATE

Ref. Certificate No.

NL-16564-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Electromechanical control circuit devices, auxilliary Contacts		
Applicant:	ABB Stotz-Kontakt GmbH	Eppelheimerstrasse 82 69123 HEIDELBERG	Germany
Manufacturer:	ABB Stotz-Kontakt GmbH	Eppelheimerstrasse 82 69123 HEIDELBERG	Germany
Factory:	ABB Bulgaria EOOD	1 Varna Str., 2850 PETRICH	Bulgaria
Rating and principal characteristics:	Ui = 250 V Uimp = 6 kV Ith = 5 A. For other details see Annex. See Annex		
Trade mark (if any):	ABB		
Model/Type reference:	HKF1-11		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-5-1(ed.3)		
Test Report Ref. No:	2122927.53		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: J.C. Hendriksen

Date of issue: 2009-08-10



ANNEX

CB TEST CERTIFICATE

Ref. Certificate No. NL-16564-A1

Ratings and principal characteristics:

<u>Ue</u>	<u>AC-15</u>	<u>DC-13</u>
24 V	3 A	1 A
120 V	3 A	
125 V		0,27 A
240 V	1,5 A	
250 V		0,15 A

contacts combinations of NO and NC contacts,
short circuit protective device fuse-link 10 A, type gL/gG,
IP20,
screw terminals.