



CB TEST CERTIFICATE

Ref. Certificate No.

NL-16563-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: KEMA Quality B.V.

Product: Electromechanical control circuit devices, auxilliary Contacts

Applicant: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany
69123 HEIDELBERG

Manufacturer: ABB Stotz-Kontakt GmbH Eppelheimerstrasse 82 Germany
69123 HEIDELBERG

Factory: ABB Bulgaria EOOD 1 Varna Str., Bulgaria
2850 PETRICH

Rating and principal characteristics: $U_i = 690\text{ V}$
 $U_{imp} = 6\text{ kV}$
Ith 6 A. For other details see Annex.

Trade mark (if any): ABB

Model/Type reference: HK1-11, HK1-20, HK1-02, HK1-20L, SK1-11, SK1-20, SK1-02, CK1-11,
CK1-20, CK1-02

Additional information:

Sample of product tested to be in conformity with IEC: 60947-5-1(ed.3)

Test Report Ref. No: 2122927.52

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: J.C. Hendriksen

Date of issue: 2009-08-10

Ratings and principal characteristics:

<u>Ue</u>	<u>AC-15</u>	<u>DC-13</u>
24 V	6 A	2 A
120 V	6 A	
125 V		0,55 A
240 V	4 A	
250 V		0,27 A
400 V	3 A	
600 V		0,15 A
690 V	1 A	

contacts combinations of NO and NC contacts,
short circuit protective device fuse-link 10 A, type gL/gG,
IP20,
screw terminals.