

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

Product  
Produit

Name and address of the applicant  
Nom et adresse du demandeur

Name and address of the manufacturer  
Nom et adresse du fabricant

Name and address of the factory  
Nom et adresse de l'usine

Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Trademark (if any)  
Marque de fabrique (si elle existe)  
Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

Model / Type Ref.  
Ref. De type

Additional information (if necessary may also be reported on page 2)  
Les informations complémentaires (si nécessaire,, peuvent être indiqués sur la 2<sup>ème</sup> page

A sample of the product was tested and found to be in conformity with  
Un échantillon de ce produit a été essayé et a été considéré conforme à la

As shown in the Test Report Ref. No. which forms part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat

## CERTIFICAT D'ESSAI OC

Switch Mode Power Supply (DIN Rail)

ABB Stotz-Kontakt GmbH  
HAUPTSTRASSE 14-16  
HORNBERG, 78132 Germany

ABB Stotz-Kontakt GmbH  
HAUPTSTRASSE 14-16  
HORNBERG, 78132 Germany

DONGGUAN TEAMWISE ELECTRONICS CO LTD  
1 AO BEI RD  
CROSS XIANG XIN WEST RD  
YANTIAN, FENG GANG  
DONGGUAN, 523701 GUANGDONG China

☐ Additional Information on page 2  
See Page 2

None

CP-C.1 24/10.0

Additionally evaluated to EN 60950-1: 2006 / A11: 2009 / A1: 2010 / A12: 2011 / A2:2013; National Differences specified in the CB Test Report

☒ Additional Information on page 2  
IEC 60950-1(ed.2), IEC 60950-1(ed.2);am1, IEC 60950-1(ed.2);am2

E196145-A9-CB-1 issued on 2015-05-21

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- ☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

Date: 2015-06-10

Signature:



Jan-Erik Storgaard

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)



Ref. Certif. No.

**DK-45679-UL**

Additional Information:

Ratings:

Input

100-240 VAC / 50-60 Hz / max. 3.5 A

90-300 VDC / max. 3.5 A

Output

22.5-24 VDC: 10 A / > 24-28.5 VDC: 240 W +60°C

22.5-24 VDC: 15 A / > 24-28.5 VDC: 300 W +40°C

-25...+70°C (> 60°C derating)

**Additional information (if necessary)**

**Information complémentaire (si nécessaire)**



☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

☒ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2015-06-10

Signature:

Jan-Erik Storgaard