

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Name and address of the applicant
Nom et adresse du demandeur

Name and address of the manufacturer
Nom et adresse du fabricant

Name and address of the factory
Nom et adresse de l'usine

Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Trademark (if any)
Marque de fabrique (si elle existe)

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais
constructeur

Model / Type Ref.
Ref. De type

Additional information (if necessary may also be
reported on page 2)
Les informations complémentaires (si nécessaire,,
peuvent être indiqués sur la 2^{ème} page

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

CERTIFICAT D'ESSAI OC

R600 Interface Relays Series

ABB Stotz-Kontakt GmbH
Eppelheimer Str 82
Heidelberg, 69123 Germany

ABB Stotz-Kontakt GmbH
Eppelheimer Str 82
Heidelberg, 69123 Germany

ABB Stotz-Kontakt GmbH
Eppelheimer Str 82
Heidelberg, 69123 Germany

☐ Additional Information on page 2

See Page 2



CTF Stage 2

RB
See Page 2

☐ Additional Information on page 2

IEC 60947-1(ed.5), IEC 60947-1(ed.5);am1, IEC
60947-5-1(ed.3), IEC 60947-5-1(ed.3);am1

4787007039-2 issued on 2016-04-05

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- ☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2016-04-06

Signature:

Jan-Erik Storgaard

Model Details:

RB May be followed by R,
followed by 101, 111, 121, 122,
followed by R, P, G,
followed by “-“,
followed by 5VDC, 12VDC, 24VDC, 24VUC, 48-60VUC, 115VUC, 230VUC, 60-230VUC

Ratings:

Input Voltage:

Coil Voltages:

DC-Version:

5 VDC, 12 VDC, 24 VDC,

AC/DC Version:

24 VAC/DC, 48-60 VAC/DC, 115 VAC/DC, 230 VAC/DC

60-230 VAC/DC

Output Voltage: (for all devices except RB...122A)

AC 12, 230 Vac, 6 A

AC 15, 230 Vac, 1.5 A

DC 12, 24 Vdc, 6 A

DC 13; 24 Vdc, 1 A

DC 13; 110 Vdc, 0.2 A

DC 13; 220 Vdc, 0.1 A

For RB...122A only:

AC 12, 230 Vac, 8 A

AC 15, 230 Vac, 1.5 A

DC 12, 24 Vdc, 8 A

DC 13, 24 Vdc, 1 A

DC 13, 110 Vdc, 0.2 A

DC 13, 220 Vdc, 0.1 A

Additional information (if necessary)

Information complémentaire (si nécessaire)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/nclnames

Date: 2016-04-06

Signature:



Jan-Erik Storgaard