

Features

SPD Type 1+2 Surge arrester range high discharge capability with no following current - single / three phase systems

- Surge arresters, suitable for low-voltage applications, to protect equipment against overvoltage by direct lightning strike, induced overvoltage and switching overvoltage
- To be installed at the boundary of LPZ 0 - LPZ 1 zones or higher
- Versions with combination of varistor and high-performance gas discharge tube (GDT) ensures high discharge currents and eliminates leakage currents
- No follow current
- Very low residual voltage
- Low U_p voltage
- Replaceable modules
- Upside down mounting possible (thanks to dual terminal markings and new restraint system for the replaceable module that permits its inversion)
- Visual fault signalling: Healthy/Replace
- Double screw terminal
- Remote status signalling contact: Healthy/Replace/Presence. Connector 07P.01 included
- According to EN 61 643-11
- 35 mm rail EN 60715 mounting, 36mm each pole

7P.09.1.255.0100 SPD Type 1, GDT protection for N-PE application only, for 3+1 configuration

7P.01.8.260.1025 SPD Type 1+2, varistor + GDT unipolar protection suitable to realize single phase or three phase systems (230/400 V) with the GDT protection module (7P.09)

7P.02.8.260.1025 SPD Type 1+2 for single phase system. Varistor + GDT protection L-N + GDT protection N-PE

For outline drawing see page 13

SPD specification

	N-PE		L-N	N-PE
Nominal voltage (U_N)	—	230	230	—
Maximum operating voltage (U_C)	255	260	260	255
Lightning impulse current (10/350 μ s) (I_{imp})	100	25	25	50
Nominal discharge current (8/20 μ s) (I_n)	100	30	30	50
Maximum discharge current (8/20 μ s) (I_{max})	100	60	60	100
Voltage protection level (U_p)	1.5	1.5	1.5	1.5
Temporary overvoltage - 120 min (TOV)	—	440	440	—
Ability to independently switch off the following current (I_f)	100	No following current	No following current	100
Response time (t_d)	100	100	100	100
Short-circuit proof at maximum overcurrent protection kA_{rms}	—	50	50	—
Maximum overcurrent protection (fuse rating gL/gG)	—	250 A	250 A	—
Maximum overcurrent protection for serial connection	—	125 A gL/gG	125 A gL/gG	—
Replacement module code	7P.00.1.000.0100	7P.00.8.260.0025	7P.00.8.260.0025	7P.00.1.000.0050

Other technical data

Ambient temperature range	°C	-40...+80	
Protection degree		IP20	
Wire size		solid cable	stranded cable
	mm²	1x2.5...1x50	1x2.5...1x35
	AWG	1x13...1x1	1x13...1x2
Wire strip length	mm	11	
Screw torque	Nm	4	

Remote status signalling contact specification

Contact configuration	1 CO (SPDT)		1 CO (SPDT)		1 CO (SPDT)	
Rated current	A AC/DC		0.5/0.1		0.5/0.1	
Rated voltage	V AC/DC		250/30		250/30	
Wire size (07P.01)	solid cable		solid cable		solid cable	
	stranded cable		stranded cable		stranded cable	
	mm ²	1.5	1.5	1.5	1.5	1.5
	AWG	16	16	16	16	16


Approvals (according to type)



7P.09.1.255.0100




- SPD Type 1
- Spark gap module for N-PE application in three phase system, 3+1 configuration
- Remote contact signalling of GDT presence
- Upside down mounting possible
- Replaceable modules



7P.01.8.260.1025




- SPD Type 1+2
- Combination of varistor and encapsulated spark gap (for single or three phase systems)
- Visual fault and remote contact fault signalling varistor/GDT status
- Upside down mounting possible
- Replaceable modules



7P.02.8.260.1025



- SPD Type 1+2
- Combination of varistor and encapsulated spark gap (for single phase systems)
- Visual fault and remote contact fault signalling varistor/GDT status, N-PE GDT presence
- Upside down mounting possible
- Replaceable modules



Features

SPD Type 1+2 Surge arrester range - three phase high discharge capability with no following current - system (230/400 V)

- Surge arresters, suitable for low-voltage applications, to protect equipment against overvoltage by direct lightning strike, induced overvoltage and switching overvoltage
- To be installed at the boundary of LPZ 0 - LPZ 1 zones or higher
- Combined high energy varistor block and heavy duty encapsulated spark gap (GDT) ensures high discharge current and eliminates leakage current
- No follow current
- Very low residual voltage
- Low U_p voltage
- Replaceable modules
- Upside down mounting possible (thanks to dual terminal markings and new restraint system for the replaceable module that permits its inversion)
- Visual fault signalling: Healy/Replace
- Double screw terminal
- Remote status signalling contact: Healy/Replace/Presence. Connector 07P.01 included
- According to EN 61 643-11
- 35 mm rail EN 60715 mounting, 36mm each pole

7P.03.8.260.1025 SPD Type 1+2 for three phase system without Neutral (PEN conductor). Varistor + GDT protection L1, L2, L3-PEN

7P.04.8.260.1025 SPD Type 1+2 for three phase system with Neutral. Varistor + GDT protection L1, L2, L3-N + spark gap protection N-PE

7P.05.8.260.1025 SPD Type 1+2 for three phase system with Neutral. Varistor + GDT protection L1, L2, L3-N + varistor + GDT protection N-PE

For outline drawing see page 13, 14

SPD specification		L-PEN		L-N	N-PE	L, N-PE	
Nominal voltage (U _N)	V AC	230		230	—	230	
Maximum operating voltage (U _C)	V AC	260		260	255	260	
Lightning impulse current (10/350 μs) (I _{imp})	kA	25		25	100	25	
Nominal discharge current (8/20 μs) (I _n)	kA	30		30	100	30	
Maximum discharge current (8/20 μs) (I _{max})	kA	60		60	100	60	
Voltage protection level (U _p)	kV	1.5		1.5	1.5	1.5	
Temporary overvoltage - 120 min (TOV)	AC	440		440	—	440	
Ability to independently switch off the following current (I _{fl})	A	No following current		No following current	100	No following current	
Response time (t _d)	ns	100		100	100	100	
Shortcircuit proof at maximum overcurrent protection	kA _{rms}	50		50	—	50	
Maximum overcurrent protection (fuse rating gL/gG)		250 A		250 A	—	250 A	
Maximum overcurrent protection for serial connection		125 A gL/gG		125 A gL/gG	—	125 A gL/gG	
Replacement module code		7P.00.8.260.0025		7P.00.8.260.0025	7P.00.1.000.0100	7P.00.8.260.0025	
Other technical data							
Ambient temperature range	°C	−40...+80					
Protection degree		IP20					
Wire size		solid cable			stranded cable		
	mm ²	1x2.5...1x50			1x2.5...1x35		
	AWG	1x13...1x1			1x13...1x2		
Wire strip length	mm	11					
Screw torque	Nm	4					
Remote status signalling contact specification							
Contact configuration		1 CO (SPDT)		1 CO (SPDT)		1 CO (SPDT)	
Rated current	A AC/DC	0.5/0.1		0.5/0.1		0.5/0.1	
Rated voltage	V AC/DC	250/30		250/30		250/30	
Wire size (07P.01)		solid cable	stranded cable	solid cable	stranded cable	solid cable	stranded cable
	mm ²	1.5	1.5	1.5	1.5	1.5	1.5
	AWG	16	16	16	16	16	16


Approvals (according to type)



7P.03.8.260.1025




- SPD Type 1+2
- 3 x combined varistor and encapsulated spark gap
- Visual fault and remote contact fault signalling varistor/GDT status
- Upside down mounting position
- Replaceable modules



7P.04.8.260.1025




- SPD Type 1+2
- 3 x combined varistor and encapsulated spark gap + 1 encapsulated spark gap
- Visual fault and remote contact fault signalling varistor/GDT status, N-PE GDT presence
- Upside down mounting position
- Replaceable modules



7P.05.8.260.1025



- SPD Type 1+2
- 4 x combined varistor and encapsulated spark gap
- Visual fault and remote contact fault signalling varistor/GDT status
- Upside down mounting position
- Replaceable modules



Features

SPD Type 1+2 Surge arrester range with high performance "Low U_p " - Single phase / three phase system

- Surge arrester suitable for 230/400 V system applications to prevent overvoltage effects caused by direct or indirect lightning strikes
- To be installed at the boundary of LPZ 0 and LPZ 1 zones
- Low U_p to protect sensitive equipment
- Visual indication of varistor status - Healthy/Replace
- Contact for remote signalling of varistor status. Connector 07P.01 included
- Replaceable varistor and Spark Gap modules
- Complies with EN 61 643-11
- 17.5 mm rail EN 60715 mounting for each module

7P.12.8.275.1012 SPD Type 1+2 for single phase system with Neutral.

- Varistor protection L-N + spark gap protection N-PE for single phase systems

7P.13.8.275.1012 SPD Type 1+2 for three phase system without Neutral (PEN conductor).

- Varistor protection L1, L2, L3-PEN for three phase systems
- Replaceable varistor modules

7P.12 / 7P.13
Screw terminal




For outline drawing see page 14

7P.12.8.275.1012




- SPD Type 1+2
- Replaceable Spark Gap and varistor modules (for single phase systems)
- Visual and remote signalling of varistor status



7P.13.8.275.1012



- SPD Type 1+2
- Replaceable varistor modules (for three phase systems)
- Visual and remote signalling of varistor status



SPD specification		L-N		N-PE	L-PEN	
Nominal voltage (U _N)	V AC	230		—	230	
Maximum continous operating voltage (U _C)	V AC/DC	275/350		255/—	275/350	
Lightning impulse current (10/350 μs) (I _{imp})	kA	12.5		25	12.5	
Nominal discharge current (8/20 μs) (I _n)	kA	30		40	30	
Maximum discharge current (8/20 μs) (I _{max})	kA	60		60	60	
Voltage protection level (U _p)	kV	1.2		1.5	1.2	
Ability to independently switch off the following current (I _{fi})	A	No following current		100	No following current	
Response time (t _a)	ns	25		100	25	
Shortcircuit proof at maximum overcurrent protection	kA _{rms}	50		—	50	
Maximum overcurrent protection (fuse rating gL/gG)		160 A		—	160 A	
Replacement module code		7P.10.8.275.0012		7P.10.1.000.0025	7P.10.8.275.0012	
Other technical data						
Ambient temperature range	°C	−40...+80				
Protection degree		IP20				
Wire size		solid cable			stranded cable	
	mm ²	1x1...1x35			1x1...1x25	
	AWG	1x 17...1x2			1x 17...1x4	
Wire strip length	mm	12				
Screw torque	Nm	3				
Remote status signalling contact specification						
Contact configuration		1 CO (SPDT)		—	1 CO (SPDT)	
Rated current	A AC/DC	0.5/0.1		—	0.5/0.1	
Rated voltage	V AC/DC	250/30		—	250/30	
Wire size (07P.01)		solid cable	stranded cable		solid cable	stranded cable
	mm ²	1.5	1.5	—	1.5	1.5
	AWG	16	16	—	16	16
Approvals (according to type)		CE EAC PG				

7P Series - Surge Protection Device (SPD)

Features

SPD Type 1+2 Surge arrester range with high performance "Low U_p " - three phase system

- Surge arrester suitable for 230/400 V system applications to prevent overvoltage effects caused by direct or indirect lightning strikes
- To be installed at the boundary of LPZ 0 and LPZ 1 zones
- Low U_p to protect sensitive equipment
- Visual indication of varistor status - Healthy/Replace
- Contact for remote signalling of varistor status. Connector 07P.01 included
- Replaceable varistor modules
- Complies with EN 61 643-11
- 17.5 mm rail EN 60715 mounting for each module

7P.14.8.275.1012 SPD Type 1+2 for three phase system with Neutral.

- Varistor protection L1, L2, L3-N+Spark Gap protection N-PE
- Replaceable varistor modules
- Non replaceable high discharge current spark gap

7P.15.8.275.1012 SPD Type 1+2 for three phase system with Neutral.

- Varistor protection L1, L2, L3, N-PE
- Replaceable varistor modules

7P.14 / 7P.15
Screw terminal




For outline drawing see page 14

7P.14.8.275.1012




- SPD Type 1+2
- Replaceable varistor module
- Visual and remote signalling of varistor status



7P.15.8.275.1012



- SPD Type 1+2
- Replaceable varistor module
- Visual and remote signalling of varistor status



SPD specification		L-N		N-PE	L, N-PE	
Nominal voltage (U _N)	V AC	230		—	230	
Maximum continous operating voltage (U _C)	V AC/DC	275/350		255/—	275/350	
Lightning impulse current (10/350 μs) (I _{imp})	kA	12.5		50	12.5	
Nominal discharge current (8/20 μs) (I _n)	kA	30		50	30	
Maximum discharge current (8/20 μs) (I _{max})	kA	60		100	60	
Voltage protection level (U _p)	kV	1.2		1.5	1.2	
Ability to independently switch off the following current (I _{fi})	A	No following current		100	No following current	
Response time (t _d)	ns	25		100	25	
Shortcircuit proof at maximum overcurrent protection	kA _{rms}	50		—	50	
Maximum overcurrent protection (fuse rating gL/gG)		160 A		—	160 A	
Replacement module code		7P.10.8.275.0012		—	7P.10.8.275.0012	
Other technical data						
Ambient temperature range	°C	–40...+80				
Protection degree		IP20				
Wire size		solid cable			stranded cable	
	mm ²	1x1...1x35			1x1...1x25	
	AWG	1x 17...1x2			1x 17...1x4	
Wire strip length	mm	12				
Screw torque	Nm	3				
Remote status signalling contact specification						
Contact configuration		1 CO (SPDT)		—	1 CO (SPDT)	
Rated current	A AC/DC	0.5/0.1		—	0.5/0.1	
Rated voltage	V AC/DC	250/30		—	250/30	
Wire size (07P.01)		solid cable	stranded cable		solid cable	stranded cable
	mm ²	1.5	1.5	—	1.5	1.5
	AWG	16	16	—	16	16
Approvals (according to type)		CE EAC PG				

Features

SPD Type 2 Surge arrester range for single / three phase AC systems and for DC systems

- Surge arrester suitable for AC and DC systems to protect equipment against induced overvoltage or switching transients
- To be installed at the boundary of LPZ 1-LPZ 2 zones or higher
- Visual indication of varistor status - Healthy/Replace
- Contact for remote signalling of varistor status. Connector (07P.01) included (depending on the version)
- Replaceable varistor and spark gap modules
- Complies with EN 61643-11:2012
- 17.5 mm rail EN 60715 mounting for each module

7P.21.8.075.1015 SPD Type 2, unipolar protection suitable for DC applications or low voltage AC single phase systems

- Varistor protection +/- or L/N (GND); -/+ or GND (L/N)
- Replaceable module

7P.21.8.130.1015 SPD Type 2, unipolar protection suitable for DC application or low voltage AC single phase systems

- Varistor protection +/- or L/N (GND); -/+ or GND (L/N)
- Replaceable module

7P.21.8.275.x020 SPD Type 2, unipolar protection suitable to realize single phase or three phase systems (230/400 V)

- Varistor protection L/N(GND)-GND/(L/N)
- Replaceable module

7P.21.8.440.x020 SPD Type 2, unipolar protection suitable for three phase systems (400 V AC)

- Varistor protection L/N(GND)-GND/(L/N)
- Replaceable module

7P.22.8.275.x020 SPD Type 2 for single phase system with Neutral

- Varistor protection L-N + spark gap protection N-PE
- Replaceable varistor and spark gap modules

7P.27.8.275.x020 SPD Type 2 for single phase system with Neutral


- Varistor protection L, N-PE
- Replaceable varistor modules

For outline drawing see page 14

7P.21.8.xxx.x0xx



- SPD Type 2 (1 varistor)
- Replaceable varistor module
- Visual and optional remote connector for signalling of the varistor status




* 7P.20.8.075.0015
** 7P.20.8.130.0015
*** 7P.20.8.275.0020
**** 7P.20.8.440.0020


7P.22.8.275.x020




- SPD Type 2 (1 varistor + 1 spark-gap)
- Combination of replaceable varistor and encapsulated spark gap modules
- Visual and optional remote connector for signalling of the varistor status



7P.27.8.275.x020



- SPD Type 2 (2 varistors)
- Replaceable varistor modules
- Visual and optional remote connector for signalling of the varistor status



SPD specification		075.1015	130.1015	275.1020	440.1020	L-N	N-PE	L, N-PE
Nominal voltage (U _N)	V AC/DC	60/60	110/125	230/—	400/—	230/—	—	230/—
Maximum continous operating voltage (U _C)	V AC/DC	75/100	130/170	275/350	440/585	275/—	255/—	275/—
Nominal discharge current (8/20 μs) (I _n)	kA	15	15	20	20	20	20	20
Maximum discharge current (8/20 μs) (I _{max})	kA	40	40	40	40	40	40	40
Voltage protection level at 5kA (U _{P5})	kV	0.3	0.45	0.9	1.5	0.9	—	0.9
Voltage protection level at I _n (U _P)	kV	0.4	0.6	1.2	1.9	1.2	1.5	1.2
Response time (t _a)	ns	25				25	100	25
Shortcircuit proof at maximum overcurrent protection	kA _{rms}	50			25	50	—	50
Maximum overcurrent protection (fuse rating gL/gG)		160 A			125 A	160 A	—	160 A
Replacement module code		*	**	***	****	7P.20.8.275.0020	7P.20.1.000.0020	7P.20.8.275.0020
Other technical data								
Ambient temperature range	°C	-40...+80						
Protection degree		IP20						
Wire size		solid cable					stranded cable	
	mm ²	1x1...1x35					1x1...1x25	
	AWG	1x17...1x2					1x17...1x4	
Wire strip length	mm	12						
Screw torque	Nm	3						
Remote status signalling contact specification								
Contact configuration		1 CO (SPDT)					1 CO (SPDT)	
Rated current	A AC/DC	0.5/0.1					0.5/0.1	
Rated voltage	V AC/DC	250/30					250/30	
Wire size (07P.01)		solid cable			stranded cable		solid cable	stranded cable
	mm ²	1.5			1.5		1.5	1.5
	AWG	16			16		16	16
Approvals (according to type)		CE EAC UL VDE						

Features

SPD Type 2 Surge arrester range - three phase systems

- Surge arrester suitable for 230/400 V system applications to protect equipments against induced overvoltage or switching transients
- To be installed at the boundary of LPZ 1-LPZ 2 zones or higher
- Visual indication of varistor status - Healthy/Replace
- Contact for remote signalling of varistor status. Connector (07P.01) included (depending on the version)
- Replaceable varistor and spark gap modules
- Complies with EN 61643-11:2012
- 35 mm rail (EN 60715) mounting

7P.23.8.275.1020 SPD Type 2 for three phase system without Neutral (PEN conductor).

- Varistor protection L1, L2, L3-PEN
- Replaceable varistor module

7P.24.8.275.x020 SPD Type 2 for three phase system with Neutral.

- Varistor protection L1, L2, L3 + Spark gap protection N-PE
- Replaceable varistor and spark gap modules

7P.25.8.275.x020 SPD Type 2 for three phase system with Neutral.

- Varistor protection L1, L2, L3, N-PE
- Replaceable varistor module

7P.23.8 / 7P.24 / 7P.25

Screw terminal




For outline drawing see page 15

7P.23.8.275.1020




- SPD Type 2 (3 varistors)
- Replaceable varistor module, 3 pole
- Visual and remote signalling of varistor status



7P.24.8.275.x020




- SPD Type 2 (3 varistors + 1 spark-gap)
- Combination of replaceable varistor and encapsulated spark gap modules
- Visual and optional remote connector for signalling of the varistor status



7P.25.8.275.x020



- SPD Type 2 (4 varistors)
- Replaceable varistor module, 4 pole
- Visual and optional remote connector for signalling of the varistor status



SPD specification		L - PEN		L-N	N-PE	L, N-PE	
Nominal voltage (U _N)	V AC	230		230	—	230	
Maximum continous operating voltage (U _C)	V AC/DC	275/350		275/—	255/—	275/350	
Nominal discharge current (8/20 μs) (I _n)	kA	20		20	20	20	
Maximum discharge current (8/20 μs) (I _{max})	kA	40		40	40	40	
Voltage protection level at 5kA (U _{P5})	kV	0.9		0.9	—	0.9	
Voltage protection level at I _n (U _P)	kV	1.2		1.2	1.5	1.2	
Response time (t _d)	ns	25		25	100	25	
Shortcircuit proof at maximum overcurrent protection	kA _{rms}	50		50	—	50	
Maximum overcurrent protection (fuse rating gL/gG)		160 A		160 A	—	160 A	
Replacement module code		7P.20.8.275.0020		7P.20.8.275.0020	7P.20.1.000.0020	7P.20.8.275.0020	
Other technical data							
Ambient temperature range	°C	−40...+80					
Protection degree		IP20					
Wire size		solid cable			stranded cable		
	mm ²	1x1...1x35			1x1...1x25		
	AWG	1x 17...1x2			1x 17...1x4		
Wire strip length	mm	12					
Screw torque	Nm	3					
Remote status signalling contact specification							
Contact configuration		1 CO (SPDT)		1 CO (SPDT)		1 CO (SPDT)	
Rated current	A AC/DC	0.5/0.1		0.5/0.1		0.5/0.1	
Rated voltage	V AC/DC	250/30		250/30		250/30	
Wire size (07P.01)		solid cable	stranded cable	solid cable	stranded cable	solid cable	stranded cable
	mm ²	1.5	1.5	1.5	1.5	1.5	1.5
	AWG	16	16	16	16	16	16
Approvals (according to type)		CE ENEC  					

Features

SPD Type 2 Surge arrester range for Photovoltaic applications

- Surge arrester for protection of DC side (420 V to 1,200 V) of systems in photovoltaic applications
- Protects equipment against induced overvoltage caused by lightning strikes or switching transients

7P.26.9.420.1020, $U_{CPV} = 420$ V DC

7P.23.9.750.x020, $U_{CPV} = 750$ V DC

7P.23.9.200.1015, $U_{CPV} = 1,200$ V DC

- Visual indication of varistor status - Healthy/Replace
- Contact for remote signalling of varistor status. Connector (07P.01) included (depending on the version)
- Replaceable modules
- Complies with prEN 50539-11:2010
- 35 mm rail (EN 60715) mounting

7P.23.9 / 7P.26
Screw terminal




For outline drawing see page 15

7P.26.9.420.1020




- SPD Type 2 (2 varistors + 1 spark-gap) for 420 V DC photovoltaic systems
- Combination of replaceable varistor and encapsulated spark gap modules
- Visual and remote signalling of varistor status



7P.23.9.750.x020




- SPD Type 2 (3 varistors) for 750 V DC photovoltaic systems
- Replaceable varistor modules
- Visual and optional remote connector for signalling of the varistor status



7P.23.9.200.1015



- SPD Type 2 (3 varistors) for 1200 V DC photovoltaic systems
- Replaceable varistor modules
- Visual and remote signalling of varistor status



E

SPD specification		Varistor module	Spark-gap module	Varistor module		Varistor module	
Maximum operating voltage (U _{CPV}) V DC		420		750		1200	
Maximum operating voltage /per module (U _{CPV}) V DC		375	420	375		600	
Nominal discharge current (8/20 μs) /per module (I _n) kA		20	20	20		15	
Maximum discharge current (8/20 μs) /per module (I _{max}) kA		40	40	40		30	
Voltage protection level per module (U _p) kV		1.8	1.5	1.8		2.1	
Voltage protection level of the system U _p (+ → -)/(+/- → PE) kV		3.6/1.5		3.6/3.6		4.2/4.2	
Response time (t _a) ns		25	100	25		25	
Short circuit current withstand I _{SCPV} A		63	—	63		125	
Replacement module code		7P.20.9.375.0020	—	7P.20.9.375.0020		7P.20.9.600.0015	
Other technical data							
Ambient temperature range °C		-40...+80					
Protection degree		IP20					
Wire size		solid cable		stranded cable			
		mm ²	1x1...1x35	1x1...1x25			
		AWG	1x 17...1x2	1x 17...1x4			
Wire strip length mm		14					
Screw torque Nm		3					
Remote status signalling contact specification							
Contact configuration		1 CO (SPDT)		1 CO (SPDT)		1 CO (SPDT)	
Rated current A AC/DC		0.5/0.1		0.5/0.1		0.5/0.1	
Rated voltage V AC/DC		250/30		250/30		250/30	
Wire size (07P.01)		solid cable	stranded cable	solid cable	stranded cable	solid cable	stranded cable
		mm ²	1.5	1.5	1.5	1.5	1.5
		AWG	16	16	16	16	16
Approvals (according to type)		CE EAC BFC PG					

7P Series - Surge Protection Device (SPD)

Features

SPD Type 1+2 and Type 2 Surge arrester range for Photovoltaic applications

- Surge arrester for protection of DC side (1,020 V) of systems in photovoltaic applications
- Protects equipment against overvoltage caused by direct lightning strike (Type 1+2 only) and induced overvoltages (Type 1+2 and Type 2)
- 7P.26.9.000.x015**, $U_{CPV} = 1,020$ V DC (Type 2)
- 7P.23.9.000.x015**, $U_{CPV} = 1,020$ V DC (Type 2)
- 7P.03.9.000.1012**, $U_{CPV} = 1,000$ V DC (Type 1+2)
- Visual indication of varistor status - Healthy/Replace
- Contact for remote signalling of varistor status. Connector (07P.01) included (depending on the version)
- Replaceable modules
- Complies with prEN 50539-11:2010
- 35 mm rail (EN 60715) mounting

7P.23.9 / 7P.26 / 7P.03
Screw terminal

E




For outline drawing see page 15

7P.26.9.000.x015




- SPD Type 2 (2 varistors + 1 spark-gap) for 1,020 V DC photovoltaic systems
- Combination of replaceable varistor and encapsulated spark gap modules
- Visual and optional remote connector for signalling of the varistor status



7P.23.9.000.x015




- SPD Type 2 (3 varistors) for 1,020 V DC photovoltaic systems
- Replaceable varistor modules
- Visual and optional remote connector for signalling of the varistor status



7P.03.9.000.1012



- SPD Type 1+2 (3 varistors) for 1,000 V DC photovoltaic systems
- Replaceable varistor modules
- Visual and remote signalling of varistor status



SPD specification		Varistor module	Spark-gap module	Varistor module		Varistor module	
Maximum operating voltage (U _{CPV}) V DC		1,020		1,020		1,000	
Maximum operating voltage /per module (U _{CPV}) V DC		510	1020	510		500	
Lightning impulse current (10/350 μs) /per module (I _{imp}) kA		—	—	—		12.5	
Nominal discharge current (8/20 μs) /per module (I _n) kA		15	15	15		30	
Maximum discharge current (8/20 μs) /per module (I _{max}) kA		30	30	30		60	
Voltage protection level /per module (U _p) kV		2	2.5	2		1.8	
Voltage protection level of the system U _p (+ → -)/(+/- → PE) kV		4/2.5		4/4		3.6/3.6	
Response time (t _a) ns		25	100	25		25	
Short circuit current withstand I _{SCPV} A		125	—	125		125	
Replacement module code		7P.20.9.500.0015	7P.20.1.000.9015	7P.20.9.500.0015		7P.00.9.500.0012	
Other technical data							
Ambient temperature range °C		-40...+80					
Protection degree		IP20					
Wire size		solid cable		stranded cable		solid cable	stranded cable
		mm ²		1x1...1x35		1x2.5...1x50	1x2.5...1x35
		AWG		1x17...1x2		1x13...1x1	1x13...1x2
Wire strip length mm		14				9	
Screw torque Nm		3				4	
Remote status signalling contact specification							
Contact configuration		1 CO (SPDT)		1 CO (SPDT)		1 CO (SPDT)	
Rated current A AC/DC		0.5/0.1		0.5/0.1		0.5/0.1	
Rated voltage V AC/DC		250/30		250/30		250/30	
Wire size (07P.01)		solid cable	stranded cable	solid cable	stranded cable	solid cable	stranded cable
		mm ²	1.5	1.5	1.5	1.5	1.5
		AWG	16	16	16	16	16
Approvals (according to type)		CE ENEC VDE					

Features

SPD Type 3, Surge arrester for TT and TN-S system (with Neutral)
Single phase applications within socket outlets and 35 mm rail mounting

- Protects electrical and electronic equipment sensitive to impulse overvoltage
- "1+1" configuration: varistor + spark gap protection (avoiding earth leakage current)
- Conforms to EN 61643-11

7P.32.8.275.2003

- Provides easy additional surge protection for 230 V sockets
- Acoustic indication of need to replace varistor
- 3-wires, 150 mm long, for connection to socket terminals

7P.37.8.275.1003

- Permits serial connection for optimized load protection up to 16 A
- Integrated remote signalling contact of varistor status
- Relay with gold change-over contact for reliable low level switching
- 17.5 mm L-N/N-PE protection
- Mounting on 35mm DIN rail (EN60715)

* see diagram L7P page 21
For outline drawing see page 15, 16

SPD specification

Nominal voltage (U_N)	V AC	230	230
Maximum continuous operating voltage (U_C)	V AC	275	275
Rated load current I_L	A	—	16
Nominal discharge current (8/20 μ s)			
L-N, L(N)-PE (I_n)	kA	3/3	3/3
Test voltage of the combined generator			
L-N, L(N)-PE (U_{oc})	kV	6/6	6/6
Voltage protection level L-N, L(N)-PE (U_p)	kV	1/1.5	1/1.5
Response time L-N, L(N)-PE (t_a)	ns	25/100	25/100
Short-circuit proof at maximum overcurrent protection	kA_{rms}	6	5
Maximum overcurrent protection		16A gL/gG, C16 A	16A gL/gG, B16A, C16A

Other technical data

Ambient temperature range	°C	−25...+80	−25...+70*	
Protection degree		IP 20	IP 20	
Wire size		—	solid cable	stranded cable
	mm²	—	0.5...6	0.5...4
	AWG	—	20...10	20...12
Wire strip length	mm	—	9	
Screw torque	Nm	—	0.8	

Remote status signalling contact specification


Contact configuration		—	1 CO (SPDT)	
Rated current	A AC	—	0.5	
Rated voltage	V AC	—	230	
Breaking capacity DC1: 30/110	A	—	2/0.3	
Minimum switching load	mW (V/mA)	—	10 (5/5)	
Contact material		—	AgNi + Au	

Approvals (according to type)

7P.32.8.275.2003




- SPD Type 3
- Acoustic (buzzing) signalling of varistor fault



7P.37.8.275.1003



- SPD Type 3
- Series connection for protection of loads up to 16 A
- Remote signaling of varistor status by integral change-over relay contact



Features


Data line SPD for Ethernet Cat. 6

- Suitable for Ethernet, POE (Power over Ethernet) and dataline transmission system up to 250 MHz
- Protection of all pairs of conductors with minimum attenuation
- Aluminum chassis and RJ45 in metal screens
- Included accessories for simple installation near the equipment to be protected, LPZ boundary 2-3 (Type 3)
- Complies to EN 61643-21
- Mounting on 35mm DIN rail

7P.68.9.060.0600



- Ethernet Cat 6 - 60 V
- Shielded RJ45 connectors



For outline drawing see page 16

SPD specification

Nominal voltage of system (U_N)	V DC	48
Maximum operating voltage (U_C)	V DC	60
Nominal current I_L	mA	500
C2 total nominal discharge current (8/20 μ s) line - PG (I_n)	kA	1.6
C2 nominal discharge current (8/20 μ s) line-line (I_n)	A	200
Voltage protection level line-line @ I_n (C2) - (U_p)	V	40
Voltage protection level line-PG @ I_n (C2) - (U_p)	V	350
Voltage protection level line-line @ 1kV/ μ s (C3) - (U_p)	V	65
Insertion attenuation @ 250 MHz	dB	<2
Response time	ns	1

Other technical data

Ambient temperature	°C	-40...+80
Degree of protection		IP 20
Input-Output connection		RJ45/RJ45 shielded

Approvals (according to type)



Ordering information

Example: 7P series, surge protection device, Type 2, single phase ($U_c = 275$ V), 1 varistor + 1 encapsulated spark gap, with remote status signalling contact, $I_n = 20$ kA

7 P . 2 2 . 8 . 2 7 5 . 1 0 2 0

Series

Type

- 0 = Combined type 1 + 2 arresters high discharge capability
- 1 = Type 1+2 high performance "Low U_p " surge arresters
- 2 = Type 2 surge arresters
- 3 = Type 3 surge arresters
- 6 = Data line SPD

Circuit

- 1 = Single phase (1 varistor)
- 2 = Single phase (1 varistor + 1 spark-gap)
- 3 = Three-phase (3 varistors)
- 4 = Three-phase (3 varistors + 1 spark-gap)
- 5 = Three-phase (4 varistors)
- 6 = 2 varistors + 1 spark-gap
- 7 = Single phase (2 varistors) Type 2 (7P.27)
- 8 = Single phase (1 varistor + 1 spark gap) Type 3, DIN rail mounting (7P.37)
- 9 = Protected poles (Data line SPD)
- 0 = Spare module

Supply version

- 1 = N+PE connection (only for single spark gap replaceable module and 7P.09)
- 8 = AC (50/60 Hz)
- 9 = DC (PV application and Data line SPD)

Supply voltage

- 000 = 1,000 V DC Max PV SPD T1+2 (7P.03.9), 1,020 V DC Max PV SPD T2 (7P.23.9, 7P.26.9) or N+PE connection for spark gap modules
- 060 = 60 V DC Max (U_c) and Data line SPD
- 075 = 75 V AC
- 130 = 130 V AC
- 200 = 1,200 V DC Max
- 420 = 420 V DC Max
- 750 = 750 V DC Max
- 440 = 440 V Max (U_c) for SPD Type 2 (for $U_N = 400$ V AC)
- 275 = 275 V Max for SPD Type 1+2 "Low U_p ", Type 2 (U_c) (for $U_N = 230$ -240 V AC) and Type 3
- 260 = 260 V Max (U_c) for SPD Type 1+2 (for $U_N = 230$ -240 V AC)
- 255 = 255 V Max (U_c) for SPD Type 1, N+PE (7P.09)


Nominal discharge current

- 100 = 100 kA (I_{imp} Type 1) only for 7P.09, N-PE GDT for 7P.04
- 050 = 50 kA (I_{imp} Type 1 N-PE GDT for 7P.02)
- 025 = 25 kA (I_{imp} Type 1+2)
- 020 = 20 kA (I_n Type 2)
- 015 = 15 kA (I_n Type 2)
- 012 = 12.5 kA (I_{imp} Type 1+2)
- 003 = 3 kA ($I_n @ U_{oc}$ only for 7P.32 and 7P.37)
- 600 = Ethernet Cat 6 (Data line SPD)

Remote status signalling contact

- 0 = Without remote status signalling contact (only some Type 2 SPD and Data line)
- 1 = Built-in remote status signalling contact
- 2 = Acoustic fault signalling
- 6 = Upside down screw position

Upside down mounting



7P Series - Surge Protection Device (SPD)

Replaceable modules



Replacement varistor and Spark-Gap modules	7P.00.8.260.0025	7P.00.9.500.0012	7P.00.1.000.0050	7P.00.1.000.0100
	Varistor	Varistor	Spark-Gap	Spark-Gap
Maximum operating voltage (U_C/U_{CPV}) V AC/DC	260 / —	— / 500	255 / —	255 / —
Lightning Impulse current (10/350 μ s) (I_{imp}) kA	25	12.5	50	100
Nominal discharge current (8/20 μ s) (I_n) kA	30	30	100	100
Maximum discharge current (8/20 μ s) (I_{max}) kA	60	60	100	100
Voltage protection level (U_p) kV	1.5	1.8	1.5	1.5
Response time (t_d) ns	25	25	100	100
Maximum overcurrent protection	250 A gL/gG	—	—	—



Replacement varistor and Spark-Gap modules	7P.10.8.275.0012	7P.10.1.000.0025
	Varistor	Spark-Gap
Maximum operating voltage (U_C) V AC	275	255
Lightning Impulse current (10/350 μ s) (I_{imp}) kA	12.5	25
Nominal discharge current (8/20 μ s) (I_n) kA	30	30
Maximum discharge current (8/20 μ s) (I_{max}) kA	60	60
Voltage protection level (U_p) kV	1.2	1.5
Response time (t_d) ns	25	100
Maximum overcurrent protection	160 A gL/gG	—



Replacement varistor modules	7P.20.8.075.0015	7P.20.8.130.0015	7P.20.8.275.0020	7P.20.8.440.0020
	Varistor	Varistor	Varistor	Varistor
Maximum operating voltage (U_C) V AC/DC	75/100	130/170	275 / 350	440/585
Nominal discharge current (8/20 μ s) (I_n) kA	15	15	20	20
Maximum discharge current (8/20 μ s) (I_{max}) kA	40	40	40	40
Voltage protection level (U_p) kV	0.4	0.6	1.2	1.5
Response time (t_d) ns	25	25	25	25
Maximum overcurrent protection	160 A gL/gG	160 gL/gG	160 gL/gG	125 gL/gG



Replacement varistor modules	7P.20.9.375.0020	7P.20.9.500.0015	7P.20.9.600.0015
	Varistor	Varistor	Varistor
Maximum operating voltage (U_C/U_{CPV}) V AC/DC	— / 375	— / 510	— / 600
Nominal discharge current (8/20 μ s) (I_n) kA	20	15	15
Maximum discharge current (8/20 μ s) (I_{max}) kA	40	30	30
Voltage protection level (U_p) kV	1.8	2	2.1
Response time (t_d) ns	25	25	25
Maximum overcurrent protection	125 A gL/gG	—	—




Replacement Spark-Gap modules	7P.20.1.000.0020	7P.20.1.000.9015
	Spark-Gap	Spark-Gap
Maximum operating voltage (U_C/U_{CPV}) V AC/DC	255 / —	— / 1,020
Nominal discharge current (8/20 μ s) (I_n) kA	20	15
Maximum discharge current (8/20 μ s) (I_{max}) kA	40	30
Voltage protection level (U_p) kV	1.5	2.5
Response time (t_d) ns	100	100
Maximum overcurrent protection	—	—


Temporary Overvoltage (TOV)	7P.32.8.275.2003	7P.37.8.275.1003
Transient OverVoltage 5s L-N (U_{TOV}) V	335	335
Transient OverVoltage 5s L-PE (U_{TOV}) V	400	400
Transient OverVoltage 200 ms L-PE (U_{TOV}) V	1,430	1,430

Outline drawings


Type 7P.09
Screw terminal




Type 7P.01
Screw terminal




Type 7P.02
Screw terminal



Type 7P.03
Screw terminal




Type 7P.04
Screw terminal




E

Outline drawings


Type 7P.05
Screw terminal




Type 7P.12
Screw terminal




Type 7P.13
Screw terminal




Type 7P.14
Screw terminal




Type 7P.15
Screw terminal



Type 7P.21
Screw terminal




Type 7P.22 / 7P.27
Screw terminal




Outline drawings


Type 7P.23.8
Screw terminal




Type 7P.24
Screw terminal




Type 7P.23.9
Screw terminal




Type 7P.25
Screw terminal




Type 7P.26.9.000.1015
Screw terminal




Type 7P.26.9.420.1020
Screw terminal



Type 7P.23.9.000.6020
Screw terminal




Tipo 7P.37.8.275.1003
Screw terminal




Outline drawings



Type 7P.68.9.060.0600
Screw terminal





Type
7P.32





Type 7P.00
Replaceable module



Type 7P.10/20
Replaceable module




07P.01
Connector




Installation example - SPD Type 1 + 2


TT-SINGLE PHASE SYSTEM - SPD UP-STREAM OF RCD



TT-THREE PHASE SYSTEM - SPD UP-STREAM OF RCD




Wiring diagrams "V-shape" (fuse max = 125 A)




7P Series - Surge Protection Device (SPD)

Installation example for SPD Type 1 + 2 and Type 2 - Single phase

TT-SINGLE PHASE SYSTEM - SPD UP-STREAM OF RCD




TT or TN-S SINGLE PHASE SYSTEM - SPD DOWN-STREAM OF RCD




Installation example for SPD Type 3

TN-S SINGLE PHASE SYSTEM - SPD DOWN-STREAM OF RCD




TT or TN-S SINGLE PHASE SYSTEM - INCORPORATED IN SOCKET OUTLET




Note: suggested RCD type S

Installation example for SPD Type 1 + 2 and Type 2 - Three phase


TT-THREE PHASE SYSTEM - SPD UP-STREAM OF RCD




TT or TN-S THREE PHASE SYSTEM - SPD DOWN-STREAM OF RCD



TN-S THREE PHASE SYSTEM - SPD DOWN-STREAM OF OVERCURRENT PROTECTION




TN-C THREE PHASE SYSTEM - SPD UP-STREAM OF OVERCURRENT PROTECTION




Installation example for SPD Type 3 - Single phase


TT or TN-S SINGLE PHASE SYSTEM - SPD DOWN-STREAM OF RCD
Serial connection



TT or TN-S SINGLE PHASE SYSTEM - SPD DOWN-STREAM OF RCD
Serial connection + BUS line




TT, TN-S SINGLE PHASE: parallel connection




Function


Visual local LED signalling and remote signalling of varistor status



L7P Temperature/Current diagram for model 7P.37




Zone I: SPD and other devices installed as a group (without gap)



- A** MCB = B10A, C10A
- B** 7P.37.8.275.1003
- C** 22.32.0.xxx.x4x0

Zone II: SPD spaced, at least from one side, from components that generate heat during their operation (17.5 mm gap)



- A** MCB = B16A, C16A
- B** 7P.37.8.275.1003
- C** 22.32.0.xxx.x4x0
- (d)** 17.5 mm




- A** MCB = B16A, C16A
- B** 7P.37.8.275.1003



- B** 7P.37.8.275.1003
- D** 22.32.0.xxx.x3x0
22.32.0.xxx.x4x0

Zone III: SPD spaced, on both side, from components that generate heat during their operation (20 mm gap)





- A** MCB = B16A, C16A
- B** 7P.37.8.275.1003
- C** 22.32.0.xxx.x4x0
- (W)** 20 mm

Zone IV: SPD installed individually in free air (without significant influence from nearby components)



- B** 7P.37.8.275.1003

Installation examples - photovoltaic



SURGE VOLTAGE PROTECTORS

Surge voltage protectors (such as Finder's Surge Protection Devices, SPD) are intended to be installed in electrical systems, to protect people and machines from surge voltages that can occur on the electrical supply line and which would otherwise have disastrous consequences. These surge voltages can be atmospheric (lightning) or can originate on the electrical system due to, for example: the opening and closing of large loads, short circuits, or the switching of large power factor correction capacitors. The SPD can be described as a switch that is in parallel with the electrical system's supply line - which it is protecting. At the nominal network voltage (e.g. 230 V) the SPD appears as an open switch, having a very high impedance (almost infinite). But, under an overvoltage condition its impedance rapidly falls to near 0Ω . This effectively applies a short circuit across the supply lines and immediately "drains" the overvoltage to earth. In this way the supply line is protected wherever an SPD is installed. When the overvoltage has passed, the SPD impedance rises rapidly and resumes the state of an open switch again.




Figure 1: Ideal operation of an SPD

SPD technologies

Finder surge voltage protectors use either varistors or spark gaps.

Varistor: This can be considered as a variable resistance that at nominal voltage has a very high ohmic value. But the resistance rapidly falls to near zero as the voltage surges. In this way the varistor applies a near short circuit which clamps the surge voltage. The varistor is however subject to progressive degradation due to the small leakage current that occurs at the nominal voltage, and with the number of interventions. With every overvoltage that occurs the leakage current rises and accelerates the end of life for the device - which is ultimately indicated by the change from green to red in the signal-window.

Spark gap: This comprises two electrodes separated by air, or a gas. When a surge voltage occurs an electrical arc bridges the gap and a surge current flows to limit the surge voltage to a low and constant level. The arc extinguishes only when the surge current falls below about 10 ampere. The gas guarantees a constant level of breakdown voltage since the arc is struck in a protected environment; not exposed to pressure or humidity variations or impurities as would happen if it had occurred in air. There is however, a delay before the device arcs and the surge current is diverted, and this is dependent on the magnitude of the original voltage surge and on its rate of rise. Therefore, the voltage protection level can vary, although it is guaranteed to be less than U_p .

Component	Symbol	Leakage current	Energy dissipated	Response time	Voltage/Current characteristic
Ideal		0	High	Fast	
Spark gap		0	High	Medium	
Varistor		Very Low	Medium	Fast	

Figure 2: SPD component characteristics.

Installation (Overvoltage) categories

Choosing the SPD requires matching the Rated Impulse Voltage of the SPD with that of the equipment to be protected. This in turn relates to the Installation category (Overvoltage category). Installation categories are described within IEC 60664-1, which for a 230/400 V installation prescribes as follows:

- **Installation category I:** 1.5 kV for "particularly sensitive" equipment (e.g. electronic devices like PC or TV set);
- **Installation category II:** 2.5 kV for "user" equipment subject to "normal" impulse voltages (e.g. household electrical appliances, mobile items);
- **Installation category III:** 4 kV for equipment that are part of a fixed installation (e.g. switchboards, switches)
- **Installation category IV:** 6 kV for equipment installed at or near the origin of main incoming supply mains (e.g. energy meters).

Lightning Protection Zones and installation considerations

International standards refer to the various Lightning Protection Zones by the letters LPZ followed by an appropriate number.

- LPZ OA: An external area, where a direct lightning strike is possible and where there is total exposure to the electromagnetic field induced by the lightning.
- LPZ OB: An external area, but below a lightning conductor providing direct lightning strike protection. There remains total exposure to the electromagnetic field.
- LPZ 1: Area within a building - therefore protected from direct lightning strike. The electromagnetic field will be attenuated, depending on the degree of shielding. This zone has to be protected by SPD type 1 device(s) at its boundary with the LPZ OA or OB zone.
- LPZ 2: An area, typically a room, where the lightning current has been limited by preceding surge protectors. This zone has to be protected by SPD type 2 device(s) at its boundary with the LPZ 1 zone.
- LPZ 3: An area within a room where the lightning current has been limited by preceding surge protectors (typically the wiring after a socket or an area within a metal enclosure). This zone has to be protected by SPD type 3 device(s) at its boundary with the LPZ 2 zone.

On the following picture (Figure 3, representation is not binding) it is shown that the transition from a protection zone to the next is through the installation of SPD. SPD Type 1 must be connected upstream the system, at the point of delivery connection. As an alternative it is possible to use SPD Type 1+2. The grounding conductor must have a minimum section of 6 mm² for SPD Type 1, of 4 mm² for SPD Type 2, and 1.5 mm² for SPD Type 3 (If the building has an LPS, reference should be made to CEI 81-10/4 for the correct dimension of the cable).




Figure 3: Typical relationship between Lightning Protection Zones, Installation Categories and SPD types

Rated values and marking common to all SPD

[U_c] Maximum continuous operating voltage: Under this voltage the SPD is guaranteed to appear as an "open switch". This voltage is normally at least equal to the nominal supply voltage (U_N) + 10%. For the Finder SPD, U_c is specified as 275 V.

[U_p] Voltage protection level: This is the highest voltage level seen across the SPD during its intervention. For example, for Finder SPD Type 2, this means that a 4kV overvoltage would be limited by the SPD to a maximum 1.2 kV. Consequently, electronic devices such as PC, TV, stereo, etc. are protected - as their own internal protection will handle overvoltages U_p to 1.5 kV.

To better understand this concept; imagine that the SPD is a switch in series a low resistance. In the case of an overvoltage the switch closes and all the current goes through the resistance. According to Ohm's law the voltage developed across the resistance will be this resistance x the current ($V = R \times I$), and will be limited to $< U_p$.




Figure 4: Overvoltage limiting

Short circuit proof: A further characteristic, not normally marked on the product but important for its correct installation, is the Short circuit proof at maximum overcurrent protection. This is the maximum short-circuit current that the SPD is able to withstand when it is installed with additional maximum overcurrent protection - such as a fuse rated in accordance with the value stated under the SPD specification. Consequently the maximum prospective short-circuit current of the system at the point of installation of the SPD must not exceed this value.

Rated values and marking of SPD Type 1

SPD Type 1 must be connected upstream the system, at the point of delivery of power energy. SPD protects building and people from the risk of direct lightning (fire and death) and are characterized by:

[I_{imp} 10/350] Impulse current: I_{imp} corresponds to the peak value of a 10/350 μs current impulse waveform. This waveform represents a direct lightning strike and is used in tests to prove the performance of SPD type 1 devices.




Figure 5: 10/350 μs current waveform

Comparison of the waveforms in figures 5 and 6 shows the much higher energy content controlled by the type 1 SPD.

[I_n 8/20] Nominal discharge current: The peak current (and waveform shape) through the SPD under conditions prescribed by EN 62305 to represent the surge current as a consequence of a lightning strike to the electric supply line.




Figure 6: 8/20 μs current waveform

Rated values and marking of SPD Type 2

SPD Type 2 devices are designed to remove all the overvoltage from supply circuits that are not likely to be directly hit by lightning. SPD Type 2 are connected downstream SPD Type 1 or SPD Type 1+2, (minimum distance 1 m) and they protect machine and tools connected to the ground and reduce the risk of economic loss. SPD Type 2 are characterized by:

[I_n 8/20] Nominal discharge current: The peak current (and waveform shape) through the SPD under conditions prescribed by EN 62305 to represent the surge current as a consequence of a lightning strike to the electric supply line.

[I_{max} 8/20] Maximum discharge current: Peak value of the highest current of a 8/20 μs waveform that an SPD can discharge at least once without breaking.

Rated values and marking of SPD Type 3

SPD type 3 devices are used to protect the end user from overvoltage. They may be installed in supply networks where SDP types 1 and/or 2 already exist. They can be installed in fixed or mobile sockets and have the following characteristic parameters.

U_{oc}: test voltage. This is the peak value of the no load voltage of the combined test-generator; this has a waveform of 1.2/50 μs (figure 7) and can supply at the same time current with waveform 8/20 μs (figure 6).





Figure 7: 1.2/50 μs voltage waveform

Suggestion for the connection

The correct connection of SPD requires a shortest as possible connection to the local equipotential bar, to which are connected PE cables of the equipment to be protected. From the local equipotential bar there is a connection to the EBB. The phase wiring remains appropriate to the load.



Short-circuit protection for the SPD is provided by the overcurrent protective devices (fuses type gL/gG) recommended.

If the overcurrent protective devices F1 (which are part of the installation) have a rating smaller than or equal to the maximum recommended rating for the overcurrent protective devices for the SPD, then F2 (back up fuse), can be omitted.

7P.0X:

If $F1 > 250 \text{ A}$, then $F2 = 250 \text{ A}$

If $F1 \leq 250 \text{ A}$, $F2$ can be omitted


7P.1X, 7P.2X:

If $F1 > 160 \text{ A}$, then $F2 = 160 \text{ A}$

If $F1 \leq 160 \text{ A}$, $F2$ can be omitted


Coordination of SPD

Optimal protection from surges requires cascaded coordinated SPDs. Coordination has the purpose of splitting the energy associated with voltage across the SPDs and it is achieved by introducing an impedance between the SPDs, or alternatively, by connecting them using wires having the minimum length indicated in the figures below, in order to use the cable's own impedance.



V-shape connection


Using a V-shaped connection eliminates transferring downstream the inductive voltage generated by the surge current in the connecting wire to the SPD. This increases the protection to the system and equipment downstream. A limitation of this connection is that the nominal current for the downstream system is limited to 125A, which is the maximum current permitted through the double SPD terminals.



For systems where the rated current is greater than 125 A, it is necessary to connect the SPD in parallel with the equipment (E/I).

Connecting cable

Depending on the type of connection, serial (V-shape) or parallel (T-shape), ensure that both the maximum cable lengths and minimum cross section of the connecting wires are respected in accordance with the information below (IEC 60634-5-534):



The section of the connecting wires (copper) must not be less than:
 SPD Tipo 1: 16 mm² if it is subject to discharge a significant lightning current, 6 mm² otherwise
 SPD Type 2: 6 mm²
 SPD Type 3: 1.5 mm²

PROTECTING PHOTOVOLTAIC (PV) SYSTEMS AGAINST LIGHTNING**Installation characteristics**

[U_{OCSTC}] PV voltage: Open circuit voltage, measured under standardized test conditions, of the PV module, panel, array, or the DC side of the photovoltaic inverter. prEN50539-12.

[I_{SCSTC}]: Short-circuit current: Short-circuit current, measured under standardized test conditions, of the PV module, panel, array, or photovoltaic inverter. prEN50539-12.

[U_{CPV}] SPD Maximum continuous operating voltage: Must be equal or greater than to 1.2 times U_{OCSTC} in all conditions of radiation and temperature. prEN50539-11, prEN50539-12.

[I_{SCPV}]: Maximum prospective short-circuit current from the power system for which the SPD, in conjunction with the disconnectors specified, is rated. EN50539-11.

System installation

Photovoltaic systems are generally located external to a building and can be subjected to the direct or indirect effects of lightning.

Whilst the installation of photovoltaic panels on the roof does not, in itself, increase the risk of direct lightning, the only practical way to protect against the effects of a direct lightning strike would be the use of a lightning protection system (LPS).

The indirect effects of lightning can however, be mitigated by the appropriate use of Surge Protection Devices (SPD). These indirect effects occur when lightning strikes in proximity to the structure and where magnetic induction creates an overvoltage in the conductors – a danger to both people and equipment. In particular, the DC cables of a PV system would be exposed to the high conducted and radiated disturbances caused as a result of the lightning currents. In addition, overvoltages in PV systems are not only of atmospheric origin. It is also necessary to consider overvoltages due to switching on electrical networks connected to them. These overvoltages can also damage both the inverter and the PV panels, and this explains the need to protect the inverter on both DC and AC sides.

Photovoltaic system on a building without a lightning protection system (LPS)

As an example, Figure 10 represents a simplified photovoltaic system placed on a building without lightning rod. In such a system, the protection against lightning must be considered at the following points of installation:

- DC input of the inverter
- AC output of the inverter
- Low voltage supply network

At the DC input to the inverter SPDs specific for photovoltaic systems must be installed, according to the PV system voltage. At the inverter AC output, type 2 surge arresters must be installed suitable for the type of system. At the point of connection to the LV supply network, install type 2 surge arresters suitable to the type of system (TT, TN). In more complex systems, it might be necessary to introduce additional SPDs. DC side: if the distance between the inverter and PV modules exceeds 10 m, it is necessary to replicate and install the SPD as close as possible to the PV modules.




Figure 10: example of a photovoltaic system located on a building without LPS, protected on the DC side by an SPD with $U_{OCSTC} = 420$ V, and on the AC side by a 7P.22, specific for TT systems.

Photovoltaic system on a building with a lightning protection system (LPS)

Where an LPS exists it is good practice to install the photovoltaic panels in the area protected by the lightning rod.

In addition it is necessary to realize a good equipotential bonding system, which must be positioned as close as possible to the entry point of LV supply into the structure. The LPS, the SPD and all metal parts have to be connected to this equipotential system.

SPD protection on the DC depends on the safety distance (referred in EN50539-12:12-2012).


Note that under EN 62305 installation of a Type 1 SPD is mandatory at the point of delivery of the AC electricity supply, whether or not the building has LPS (with or without solar panels).

SPD fuse protection

Conforming to prEN50539-11: 2010, Finder SPDs are equipped with a thermal disconnecter able to safely disconnect a worn or damaged varistor up to a value of short-circuit current equal to the short-circuit current withstand value (I_{scpv}), as specified in the technical data. Ensure that the PV short circuit current $I_{sc} < I_{scpv}$. Ensure that the PV short circuit current $I_{sc} < I_{scpv}$ or increase the number of the strings.

Insulation distances and wiring

To conform with prEN50539-11 insulation distances and minimum wiring cross section must be respected.



Insulation distances		Minimum Wiring [mm ²]	
$U_{CPV}(SPD) \geq 1.2 \times U_{OCSTC}$	A [mm]	+/- Poles	Ground
750 V DC	5	4	6
1,000 V DC	5	4	6
1,200 V DC	7	4	6

