



F&F Filipowski L.P.  
Konstantynowska 79/81, 95-200 Pabianice, POLAND  
phone/fax (+48 42) 215 23 83 / (+48 42) 227 09 71  
www.fif.com.pl; e-mail: biuro@fif.com.pl

## AZ-112

Light dependent relay,  
with hermetic probe



**Do not dispose of this device in the trash along with other waste!**

According to the Law on Waste, electro coming from households free of charge and can give any amount to up to that end point of collection, as well as to store the occasion of the purchase of new equipment (in accordance with the principle of old-for-new, regardless of brand). Electro thrown in the trash or abandoned in nature, pose a threat to the environment and human health.



### Purpose

Light dependent relay servers to switch-ON the lighting of streets, squares, shop windows, neon lamps etc, at twilight and to switch-OFF afore mentioned lighting at dawn.

### Functioning

The probe of relay should be situated at place with permanent access to day light, which, due to its changes of intensity, will cause switching ON and OFF the lighting. The exact time of switching the lighting can be set by potentiometer by the user. Turn in the direction of „half moon” will delay switching-ON, turning in the direction of „sun” will advance switching-ON. The relay is equipped with a delay system, which delays switching ON and OFF the lighting, thus eliminating the influence of accidental disturbances like thunder lightings on the relay functioning.


## Mounting

1. Turn off the power supply.
2. Mount the relay on a rail in the control box.
3. Mount the probe in a place that is not illuminated by a switched (or other) light source. The relay connect with connection diagram.
4. Connect the power supply and the controlled receiver according to the diagram.
5. Use a screwdriver to set the tripping threshold.




In the case of check the power to act the relay, all relay should be securely covered, e.g. by carton or dark mine cloth. Covered just probe „eye”, e.g. by finger is insufficient because intensity of day light is very intense and penetrate to fotoresistor by the plastic box and human body.

## Description of terminals



1-3 power supply 230 V  
7-9 probe terminals  
10-12 NO separated contact

## Connection diagram



## Technical data

|                                   |                                     |
|-----------------------------------|-------------------------------------|
| power supply                      | 195÷253 V AC                        |
| maximum load current (AC-1)       | 16 A                                |
| contact configuration             | NO                                  |
| contact separation                | yes                                 |
| activation threshold (adjustable) | 2÷1000 lx                           |
| hysteresis                        | approx. 15 lx                       |
| on delay                          | approx. 10 s                        |
| off delay                         | approx. 20 s                        |
| power consumption                 | 0.56 W                              |
| terminal                          | 2,5 mm <sup>2</sup> screw terminals |
| tightening torque                 | 0.4 Nm                              |
| working temperature               | -25÷50°C                            |
| dimensions                        | 1 module (18 mm)                    |
| mounting                          | on TH-35 rail                       |
| protection level                  |                                     |
| automat                           | IP20                                |
| probe                             | IP65                                |

## Power table


|                                                                                   |                                                                                   |                                                                                   |                                                                                   |                                                                                   |
|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|
|  |  |  |  |  |
| tungsten                                                                          | halogen                                                                           | fluorescent                                                                       | energy-saving                                                                     | LED                                                                               |
| 2000 W                                                                            | 1250 W                                                                            | 1000 W                                                                            | 500 W                                                                             | 250 W                                                                             |

The above data are indicative and will heavily depend on the design of a specific receiver (that is especially important for LED bulbs, energy-saving lamps, electronic transformers and pulse power supply units), switching frequency and operating conditions.

For more information visit: [www.fif.com.pl](http://www.fif.com.pl).

## Hermetic external probe $\varnothing 10$

Small, easy-to-install photosensitive sensor equipped with a 1 m cable, extendable up to 10 m. Cable should be connected in a hermetic box or in a place free from atmospheric influence.



Do not lead the probe connection cables close to a parallel, live, and high current cables.

## Warranty

The F&F products are covered by a warranty of the 24 months from the date of purchase. Effective only with proof of purchase. Contact your dealer or directly with us.

## CE declaration

F&F Filipowski L.P. declares that the device is in conformity with the essential requirements of The Low Voltage Directive (LVD) 2014/35/EU and the Electromagnetic Compatibility (EMC) Directive 2014/30/UE.

The CE Declaration of Conformity, along with the references to the standards in relation to which conformity is declared, can be found at [www.fif.com.pl](http://www.fif.com.pl) on the product page.

