



F&F Filipowski L.P.
Konstantynowska 79/81, 95-200 Pabianice, POLAND
phone/fax (+48 42) 215 23 83 / (+48 42) 227 09 71
www.fif.com.pl; e-mail: biuro@fif.com.pl

PK-1P 24 V

Electromagnetic
relay



51190831215956321

Do not dispose of this device in the trash along with other waste! According to the Law on Waste, electro coming from households free of charge and can give any amount to up to that end point of collection, as well as to store the occasion of the purchase of new equipment (in accordance with the principle of old-for-new, regardless of brand). Electro thrown in the trash or abandoned in nature, pose a threat to the environment and human health.



Purpose

Electromagnetic relay in single-module housing for direct mounting on TH-35 rail.


Functioning

Applying the supply voltage to the relay coil will switch the contacts to position 11-12. This state is indicated by a green LED. After a power failure, the contacts return to position 11-10.

Assembly

1. Switch off the power supply.
2. Mount the relay on the rail in the distribution box.
3. Connect the power supply to terminals 1-3 (in any order).
4. Connect the power supply circuit of the controlled receiver via contacts 11-12 (NO contact).

Connecting diagram



- 1-3 power supply 24 V AC/DC
- 10 NC break contact (passive)
- 11 COM common contact
- 12 NO closing contact (active)

Technical data

power supply	24 V AC/DC
maximum load current (AC-1)	16 A*
switching voltage	250 V AC
contact	1×NO/NC
usage category	AC-7a
insulation voltage	400 V
surge voltage	
contacts-coil	2.5 kV
contact separation	1.2 kV
surge resistance	3 kV
current consumption	25 mA
activation time	<40 ms
deactivation time	<20 ms
mechanical durability	min. 5×10^6 cycles
electrical durability	min. 1×10^5 cycles
power indicator	LED
power consumption	25 mA
working temperature	-25÷50°C
terminal	screw terminals 2.5 mm ²
tightening torque	0.4 Nm
dimensions	1 module (18 mm)
mounting	on TH-35 rail
protection level	IP20

* modular contactors are recommended

Warranty

F&F products are covered by a 24-month warranty from the date of purchase. The warranty is only valid with proof of purchase. Contact your dealer or contact us directly.

CE declaration

F&F Filipowski L.P. declares that the device is in conformity with the essential requirements of The Low Voltage Directive (LVD) 2014/35/EU and the Electromagnetic Compatibility (EMC) Directive 2014/30/UE.

The CE Declaration of Conformity, along with the references to the standards in relation to which conformity is declared, can be found at www.fif.com.pl on the product subpage.