Ref. Certif. No.
NL-54655

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Luminaire for emergency lighting with LED light source
Name and address of the applicant	COOPER SECURITE SAS Rue Beethoven 63204 Riom France
Name and address of the manufacturer	Cooper Csa S.r.l. Via San Bovio,3 – Edificio Y 20090 Segrate (MI) Italy
Name and address of the factory Note: *When more than one factory, please report on page 2*	☐ Additional information on page 2 COOPER INDUSTRIES ROMANIA S.R.L. Zona Industrială NV Strada III, Nr. 12 310510 Arad Romania
Ratings and principal characteristics	220-230 V, 50/60 Hz, Class II; IP42 or IP65. ta 5 – 45 °C Duration 180 minutes.
Trademark (if any)	EATON
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	SafeLite 20 m and SafeLite 30 m
Additional information (if necessary may also be reported on page 2)	☐ Additional information on page 2 Refer to CB Test Report for the entire list of models covered by the certificate. The luminaire can be mounted on the recessed ceiling by means the accessories: SL2RB, SL3RB. The luminaire can be mounted on the recessed wall by means the accessory: SL2WB
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014, IEC 60598-2-22:2014 National differences: EU Group Differences, SA Comments: This certificate replaces certificate No. NL-48060 which we herewith declare invalid
As shown in the Test Report Ref. No. which forms part of this Certificate	3506076.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

DEKRA

Firmato digitalmente da
MASSIMILIANO TRIULZI

Date: 2018-10-25

Signature: M.Triulzi